

EPA Evacuation Level Chart

Class I & II ODS Refrigerants: HFCs go to "0" Psig

Type of Appliance	Recovery Units Manufactured Date	
	Before Nov. 15, 1993 (Grandfathered Unit)	After Nov. 15, 1993 (ARI/UL Unit)
Very high-pressure appliance. R-13, R-503	0	0*
High-pressure appliance or isolated component of such appliance, normally containing less than 200 pounds of refrigerant. R-401A/B, R-22, R-411A/B, R-502, R-402A/B, R-408A, R-409A	0	0
High pressure appliance, containing <u>200 pounds or more</u> of refrigerant.	4	10
Medium-pressure appliance or isolated component of such appliance, normally containing less than 200 pounds of refrigerant. R-114, R-124, R-12, R-401C, R-406A, R-500	4	10
Medium-pressure appliance, containing <u>200 pounds or more</u> of refrigerant.	4	15
Low-pressure appliance R-11, R-113, R-123	25	25 mm Hg absolute
* = Inches of Hg vacuum relative to standard atmospheric pressure of 29.9 inches of Hg, except where noted		