

Part IA: WASTEWATER DISCHARGE LIMITATIONS AND MONITORING

REQUIREMENTS: LOCAL LIMITS¹

All discharges shall comply with the effluent limitations specified below as well as all other applicable laws, regulations, standards, and requirements contained in District Ordinance No. 44 and any applicable State and Federal pretreatment laws, regulations, standards, and requirements and any which may become effective during the term of this permit:

<u>PARAMETER</u>	<u>INSTANTANEOUS</u> <u>LIMIT, mg/L</u>	<u>EPA APPROVED</u> <u>TEST METHOD</u>	<u>SAMPLE TYPE</u>
1,1 ,2,2-Tetrachloroethane	0.628	624	grab
1, 2-Dichlorobenzene	0.007	624	grab
1,2-Dichloroethane	104.228	624	grab
1,4-Dichlorobenzene	0.044	624	grab
2,4-Dinitrotoluene	104. 228	625	24 hr comp
4,4'-DDD	0.001	608	24 hr comp
4,4'-DDE	0.001	608	24 hr comp
4,4'-DDT	0.001	608	24 hr comp
Acenaphthene	none	625	24 hr comp
Acrylonitrile	0.157	624	grab
Aldrin	0.011	625	24 hr comp
Ammonia (Nitrogen)	109.157	SM4500-NH ₃ H	grab
Arsenic	0.095	200.7, 200.8	24 hr comp
Benzidine	0.157	625	24 hr comp
BOD	3000.0	SM 52108	24 hr comp
Cadmium	0.045	200.7, 200.8	24 hr comp
Carbon Tetrachloride	0.091	624	grab
Chlordane	0.002	625	24 hour comp
Chloroform	0.031	624	grab
Chloromethane	0.10	624	grab
Chromium (T)	2.370	200.7, 200.8	24 hr comp
Copper	0.740	200.7, 200.8	24 hr comp
Cyanide (T)	2.790	SM4500-CN	grab
Dieldrin	0.064	625	24 hr comp
Endrin	0.002	625	24 hr comp
Flouranthene	none	625	24 hr comp
Heptachlor	0.003	625	24 hr comp
Lead	1.040	200.7, 200.8	24 hr comp
Mercury	0.025	245.1	24 hr comp
Methylene Chloride	3.143	624	grab
Nickel	0.550	200.7, 200.8	24 hr comp
PCB's	0.002	625	24 hr comp
Pentachlorophenol	0.063	625	24 hr comp
Phenol	21. 679	625	24 hr comp
Selenium	0.160	200.7, 200.8	24 hr comp
Silver	0.470	200.7, 200.8	24 hr comp
Suspended Solids	2500.0	SM 25400	24 hr comp
Tetrachloroethylene	zero discharge	624	grab
Thallium	0.064	200.7, 200.8	24 hr comp
Toxaphene	0.006	625	24 hr comp
Trichloroethylene	0.629	624	grab
Trichlorofluoromethane	0.022	624	grab
Zinc	3.010	200.7, 200.8	24 hr comp
pH	6-9 units	SM4500-H B	grab

Radioactivity—not to exceed limits specified in Sections 30285 and 30287 of the California Administrative Code.

(T) = Total

Laboratory analysis of industrial wastewater samples shall be performed in accordance with 40 CFR 136 and amendments thereto.

¹ Samples collected for the purpose of determining compliance with local limits shall be obtained from the "End of Pipe" sample point designated as: (a) The sample manhole located at: The east entrance to UCSB campus on the south side of Ward Memorial. See photos on page 12.